

▶ Hanover Risk Solutions

Sprinkler System— Dry Pipe Valves, Inspection and Testing Checklist

Regular inspection, testing, and maintenance of dry-pipe sprinkler valves and associated quick-opening devices are critical to ensure effective performance of a sprinkler system. All inspections and tests should be performed in accordance with NFPA 25, *Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems*, published by the National Fire Protection Association (NFPA), as follows:

Weekly Inspections

	YES	NO	NA
Is the temperature of the enclosure, room, or area for the valve at least 40°F (4°C)? Is the enclosure, room, or area equipped with a low temperature alarm?			
Does the supply-side pressure gauge indicate normal water supply pressure?			
Are the dry-side pressure gauge readings within manufacturer’s specifications? If the system is equipped with a low pressure alarm, this inspection can be performed monthly.			
Does the quick-opening device gauge, if so equipped, indicate the same pressure as the dry-side system pressure?			

Monthly Inspections

	YES	NO	NA
Does the valve assembly show no sign of leaking or physical damage?			
Are all valves in the ready (i.e., open or closed) positions, as indicated by the system diagrams?			

Annual Inspections

	YES	NO	NA
Is the interior surface of valve body free from corrosion?			

Quarterly Testing

	YES	NO	NA
Is the priming water filled to proper level, as per the manufacturer's specifications?			
Does the quick-opening device activate properly?			
Does the low air pressure alarm function properly?			

Annual Testing

	YES	NO	NA
Is a limited-flow, trip test of the dry-pipe system and quick-opening devices performed during warm weather?			
Is a low temperature alarm function performed at the beginning of the heating season?			
Are air pressure maintenance devices tested?			

Multi-Year Inspections and Tests

	YES	NO	NA
Are all system strainers, filters, and restricting devices tested every five years for corrosion and obstructions?			
Is a full-flow, system trip test, including the quick opening, performed every three years?			
Are system gauges tested or replaced every five years? Gauges should be accurate to within three percent of full scale.			

▶ To learn more about Hanover Risk Solutions, visit hanoverrisksolutions.com



The Hanover Insurance Company
440 Lincoln Street, Worcester, MA 01653

hanover.com
The Agency Place (TAP)—<https://tap.hanover.com>

Copyright ©2012 ISO services, Inc.

The recommendation(s), advice and contents of this material are provided for informational purposes only and do not purport to address every possible legal obligation, hazard, code violation, loss potential or exception to good practice. The Hanover Insurance Company and its affiliates and subsidiaries ("The Hanover") specifically disclaim any warranty or representation that acceptance of any recommendations or advice contained herein will make any premises, property or operation safe or in compliance with any law or regulation. Under no circumstances should this material or your acceptance of any recommendations or advice contained herein be construed as establishing the existence or availability of any insurance coverage with The Hanover. By providing this information to you, The Hanover does not assume (and specifically disclaims) any duty, undertaking or responsibility to you. The decision to accept or implement any recommendation(s) or advice contained in this material must be made by you.